DATASHEET - M22-WLK3-Y



Illuminated selector switch actuator, 3 positions, yellow, momentary

M22-WLK3-Y Part no. Catalog No. 216839 Eaton Catalog No. M22-WLK3-YQ **EL-Nummer** 0004355756 (Norway)





Delivery program

| Delivery program | | |
|----------------------------------------------------------------------|---|----------------------------------------------------------------------------|
| Product range | | RMQ-Titan |
| Basic function | | Illuminated selector switch actuator |
| Single unit/Complete unit | | Single unit |
| Design | | With thumb-grip |
| | | momentary |
| Function: | | |
| | | 40° |
| | | 3 positions |
| Colour | | |
| Thumb-grip | | yellow |
| | | |
| Degree of Protection | | IP66 |
| Front ring | | Bezel: titanium |
| Connection to SmartWire-DT | | yes with SWD-RMQ connections |
| Actuator travel and actuation force as per DIN EN 60947-5-1, K.5.4.1 | | |
| Minimum force for positive opening | N | 0 |
| Front dimensions | | 29,7 |
| Instructions | | Stay-put/spring-return function, can be changed with coding parts M22-XC-Y |
| | | |

Technical data

General

| 20110101 | | | |
|-----------------------------|--------------|-------------------|--------------------------------------------------------------------------------|
| Standards | | | IEC/EN 60947 VDE 0660 |
| Lifespan, mechanical | Operations | x 10 ⁶ | > 0.1 |
| Operating frequency | Operations/h | | ≦ 2000 |
| Operating torque | | Nm | ≦ 0.3 |
| Climatic proofing | | | Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 |
| Degree of Protection | | | IP66 |
| Ambient temperature | | | |
| Open | | °C | -25 - +70 |
| Mounting position | | | As required |
| Mechanical shock resistance | | g | 30 Shock duration 11 ms Sinusoidal according to IEC 60068-2-27 |

Design verification as per IEC/EN 61439

| Technical data for design verification | | | |
|----------------------------------------------------------|------------------|---|---|
| Rated operational current for specified heat dissipation | In | Α | 0 |
| Heat dissipation per pole, current-dependent | P _{vid} | W | 0 |

| P_{vid} | W | 0 |
|-------------------|-----------------|----------------------------------------------------------------------------------------------------------------------------|
| P_{vs} | W | 0 |
| P _{diss} | W | 0 |
| | °C | -25 |
| | °C | 70 |
| | | |
| | | |
| | | Meets the product standard's requirements. |
| | | Meets the product standard's requirements. |
| | | Meets the product standard's requirements. |
| | | Meets the product standard's requirements. |
| | | Please enquire |
| | | Does not apply, since the entire switchgear needs to be evaluated. |
| | | Does not apply, since the entire switchgear needs to be evaluated. |
| | | Meets the product standard's requirements. |
| | | Does not apply, since the entire switchgear needs to be evaluated. |
| | | Meets the product standard's requirements. |
| | | Does not apply, since the entire switchgear needs to be evaluated. |
| | | Does not apply, since the entire switchgear needs to be evaluated. |
| | | Is the panel builder's responsibility. |
| | | Is the panel builder's responsibility. |
| | | |
| | | Is the panel builder's responsibility. |
| | | Is the panel builder's responsibility. |
| | | Is the panel builder's responsibility. |
| | | Not applicable. |
| | | Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:constraint}$ |
| | | Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:constraint}$ |
| | | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |
| | P _{vs} | P _{vs} W P _{diss} W °C |

Technical data ETIM 7.0

Low-voltage industrial components (EG000017) / Front element for selector switch (EC000222)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for selector switches (ecl@ss10.0.1-27-37-12-13 [AKF031014])


| Number of switch positions | | 3 |
|---------------------------------------|----|---------|
| Type of control element | | Toggle |
| Suitable for illumination | | Yes |
| Colour control element | | Black |
| Colour indicator light cap | | Yellow |
| Construction type lens | | Round |
| Hole diameter | mm | 22.5 |
| Width opening | mm | 0 |
| Height opening | mm | 0 |
| Switching function latching | | No |
| Spring-return | | Yes |
| With front ring | | Yes |
| Material front ring | | Plastic |
| Colour front ring | | Other |
| Degree of protection (IP), front side | | IP66 |
| Degree of protection (NEMA) | | 4X |
| | | |


Approvals

| Product Standards | IEC/EN 60947-5; UL 508; CSA-C22.2 No. 14-05; CSA-C22.2 No. 94-91; CE marking |
|-------------------|------------------------------------------------------------------------------|
|-------------------|------------------------------------------------------------------------------|

| UL File No. | E29184 |
|-----------------------------|----------------------------|
| UL Category Control No. | NKCR |
| CSA File No. | 012528 |
| CSA Class No. | 3211-03 |
| North America Certification | UL listed, CSA certified |
| Degree of Protection | UL/CSA Type 3R, 4X, 12, 13 |

Dimensions





Additional product information (links)

IL04716002Z (AWA1160-1745) RMQ-Titan System

IL04716002Z (AWA1160-1745) RMQ-Titan System ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/IL04716002Z2018_10.pdf